



NOTE:

REVISION #1:  
 ADDED VCB NUMBER DESIGNATIONS  
 REMOVED CT'S FROM MAIN CELLS  
 THE CT'S ARE LOCATED IN THE  
 TRANSFORMER BUSHINGS.  
 REVISION #2  
 CHANGED VCB NUMBER IN CUBICAL 68  
 FROM VCB121 TO VCB421

REVISIONS

DATE	REVISION	CHECKED BY	APPROVED
4/25/01	#1	JH	
4/27/01	#2	JH	

**INTERMOUNTAIN ELECTRONICS**

1503 SOUTH HIGHWAY 6 PRICE, UT (435) 637-7160

DATE: 4/25/01 DRAWN BY: LB  
 ACAD REF: 34567-9-WEST SCALE: NONE

**BHP**  
 SUBSTATION CONTROL BUILDING  
 UPPER LEVEL WEST SWITCHGEAR ONE LINE

JOB # 34567 SHEET # 9